

# FINISH SCHEDULE

NO	ROOM	FLOOR	BASE	WALLS	CEILING	GLG HGT DOORS	TRIM	REMARKS
			MATCOL	MATCOL	MATCOL	MATCOL	MATCOL	
101	HALL	HM	HM	MD	S-	GWB	TBD	GWB
102	BEDROOM	HM	HM	MD	S-	GWB	TBD	GWB
103	BATHROOM	CT	CT	CT	CT	GWB	TBD	GWB
104	BEDROOM	HM	HM	MD	S-	GWB	TBD	GWB
105	BATHROOM	CT	CT	CT	CT	GWB	TBD	GWB
106	WALK IN CLOSET	HM	HM	MD	S-	GWB	TBD	GWB
107	PANTRY	HM	HM	MD	S-	GWB	TBD	GWB
108	KITCHEN	HM	HM	MD	S-	GWB	TBD	GWB
109	DINING	HM	HM	MD	S-	GWB	TBD	GWB
110	LIVING AREA	HM	HM	MD	S-	GWB	TBD	GWB
III	STAIRS							

# MATERIAL AND COLOR SCHEDULE

SYM	MATERIAL	MANUFACTURER	TYPE/COLOR	REMARKS
P1	PAINT			
P2	PAINT			
S1	STAIN			
S2	STAIN			
HM	HARDWOOD			
VMK1				
VMK2				
HM	CARPET			
HM2	CARPET			
CT1	CERAMIC TILE			
CT2	CERAMIC TILE			

\* REF FINI FIRE RATINGS

2-HOUR FIRE RATED EXTERIOR WALL  
-GA DESIGN RHP R420

**INTERIOR SIDE**  
 -1/2" TYPE X GWB APPLIED PARALLEL TO STUDS  
 -1/2" NAILS TYPE A @ 12" OC  
 -FACE LAYERS 5/8" TYPE X GWB APPLIED AT RIGHT ANGLES TO STUDS  
 -STUDS 2x4 W/ NAILS TYPE B @ 8" OC AT EDGES AND 12" OC IN INTERMEDIATE STUDS

**EXTERIOR SIDE**  
 -BASE LAYER 5/8" EXT GYPSUM SHEATHING APPLIED PARALLEL TO STUDS W/ NAILS TYPE A @ 12" OC  
 -ONE LAYER FIRE RESISTANT PROTECTIVE WEATHER BARRIER PAPER STAPLED ALONG EA EDGE @ 12" OC  
 -GALV SELF-FLURING WIRE MESH APPLIED W/ GALV ROOFING NAILS TYPE B @ 8" OC  
 -CEMENT STUCCO APPLIED OVER WIRE MESH IN (2) 1/2" THK COATS W/ BONDING AGENT APPLIED BETWEEN COATS.

**PARTITION TYPE 2**

**NAIL TYPES**  
 -A- 16D COMMON NAILS, 1 7/8" LNG, 0.0915" SHANK, 1/4" HEADS  
 -B- 8D COATED NAILS, 2 3/8" LNG, 0.118" SHANK, 3/32" HEADS

**PARTITION TYPE '1A'**

**PARTITION TYPE '1I'**

# PART. TYPES

SCALE: NTS

# ROOF PLAN - UNIT #300

SCALE: 1/4" = 1'-0"

